

F-502 (8) 7'-4" of No 5 Vertical Bars for 8'-0" DEEP (8) 9'-4" of No 5 Vertical Bars for 10'-0" DEEP (24) 14'-4" of No 7 Vertical Bars for 15'-0" DEEP

All steel to be a minimum of 3" from edge of foundation.

F-503 (8) No 5 Stirrups at I'-0" centers for 8'-0" DEEP (10) No 5 Stirrups at I'-0" centers for 10'-0" DEEP

(IO) No 4 Stirrups at I'-6" centers for I5'-0" DEEP

(Alternate)


Cadweld Clamp


F-8 REINFORCING STEEL

F-501 (8) No 5 Stirrups at 1'-0" centers for 8'-0" DEEP


(IO) No 5 Stirrups at I'-0" centers for IO'-0" DEEP

(IO) No 4 Stirrups at I'-6" centers for I5'-0" DEEP





TOP VIEW




FRONT AND SIDE VIEW F-4A FOUNDATION

See F-8 for pole or B-4 for controller ground rod installation

ANCHOR BOLT INFORMATION											
MAST ARM LENGTHS	18' - 32'	34′ - 50′	55′ - 70′	19' DMS	55′ TMP	60' TMP	65' TMP	70' TMP	75′ TMP		
ANCHOR BOLT SIZE	1½"x54"x6"	13/4"×84"×6"	2"x84"x6"	1½"x60"x6"	1 1/2"x54"x6"	1½"x54"x6"	1 1/2"x54"x6"	1½"x54"x6"	1½"x54"x6"		
BOLT CIRCLE	17"	171/2"	201/2"	16"	20"	21"	23"	25"	27"		

TMP is Traffic Monitoring Pole

F-8 FOUNDATION



## B-4 CONTROLLER BASE. PAD AND GROUND ROD INSTALLATION

All steel is No 4 with a minimum 3" clearance to any edge of concrete Contractor to install an extra 3" stub from the cabinet to not under concrete

## GROUNDING

The Ground Rod for the B-4 and F-4A Controller Base shall be installed in a pull box not less than 10' from the controller. (1) No 6 & (1) No 8 USE Cable shall be installed between the controller and the ground rod. The contractor shall bond the cables at the ground rod. Connections at the controller will be by City Forces. The Ground Rod for the F-8 and F-4A Foundation shall be located 3' from the edge of the foundation and the top of the ground rod shall be I' below the finished grade. UNDER NO CIRCUMSTANCES SHALL THE GROUND ROD BE INSTALLED WITHIN THE CABINET FOUNDATION.

## CONDUIT BENDS

Conduit bends shall be 90°. They shall be located a minimum of 30 inches below ground level. There shall be a minimum of one spare conduit bend installed in each foundation with both ends plugged and free of debris and moisture. Standpipe conduit 2 inches minimum above top of finished foundation.



				FOUNDA	A TIONIC	VVID	DACEC		
				L OOMD!	4110112	ANU	DASES	)	
				5-03 / CAW					
									1
			1						